


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Director: Prof. Dr.rer.nat. Lothar Dunemann

Legal Entity: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.



Hygiene-Institut · PO Box 10 12 55 · DE 45812 Gelsenkirchen · Germany

Address:
Rotthauer Str. 21, DE 45879 Gelsenkirchen

Switchboard +49 (0)209 9242-0
Telefax +49 (0)209 9242-222
Internet www.hyg.de

Our reference: W-324154ke-20-AB
Contact person: Dipl.-Ing. (FH) S. Horn

Gelsenkirchen, 11.05.2020

Test - certificate

hygiene-conformity check to the design requirements of
selected regulations

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthauer Straße 21
49879 Gelsenkirchen

Test object: AIR COR PEHD Art. 75

Manufacturer: ITALIANA CORRUGATI S.P.A
Via Foglia 11
61026 Lunano (PU)

Basis of the examination

- ✓ VDI 6022, sheet 1 (01/2018)
- ✓ SWKI VA104-01 (01/2019)
- ✓ ÖNORM H6021 (08/2016)
- ✓ ÖNORM H6038 (02/2020)

Validity period: 5 years 04/2020 – 04/2025

Test report: W-324154k-20-AB



In conclusion it can be stated that the examined Plastic pipe "AIR COR PEHD Art. 75", as specified in the test report W-324154ke-20-AB, is in compliance with the above mentioned regulations.

(Dipl.-Ing. (FH) S. Horn)
Section head of Air Conditioning technology
Department of Water Hygiene, Environmental
and Microbiology

(A. Blankenberg)
clerk of Air Conditioning technology
State certified technician
Specialization in heating, air conditioning

issued 11.05.2020, Gelsenkirchen

Within the framework of the conformity check the hygiene-relevant requirements of the above mentioned regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the conformity check does not include a toxicological or sensory testing of the introduced materials.